

CERTIFICATION OF WORK SERVICE CALL

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: MD024 B-1 Date of Visit: 03/30,31/21

Contractor Personnel on Site:

- | | |
|---------------------------------|----------|
| 1. <u>John Brown</u> | 4. _____ |
| 2. <u>B&P Environmental</u> | 5. _____ |
| 3. <u>S&S</u> | 6. _____ |

Service Call Number

CSS# 29802 WO# 13967

Description of Repairs

B&P ENVIRONMENTAL came out and pumped out 2000 gallons out of Septic tank . I checked out the power and the pump operation. S&S came out and snake the Ladies room because the drains were still slow. everything works fine now.

CERTIFICATION OF WORK

To be signed by the Contractor:


Print Name: Johnny W Brown Date: 03/31/21

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank CW5 Mark Smith Date: 03/31/21

Signed: 

E-Mail: _____







