

**CERTIFICATION OF WORK  
SERVICE CALL**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: MD024 B-1 Date of Visit: 04/07/21

Contractor Personnel on Site:

1. <u>John Brown</u>	4. _____
2. _____	5. _____
3. _____	6. _____

**Service Call Number**

CSS# 29950 WO# 13981

**Description of Repairs**

cycled the power to the heater and turned water back on. relief valve stayed closed. I adjusted the temperature down a little but found nothing wrong. suspect the thermostat stuck closed but no way to tell. I'm keeping my eye on it.

---

**CERTIFICATION OF WORK**

To be signed by the Contractor:

Print Name: Johnny W Brown Date: 04/07/21

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: SSG Richard Gaytan Date: 04/07/21

Signed: 

E-Mail: \_\_\_\_\_

