

CERTIFICATION OF WORK
(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: MD 002

Date of Visit: 24 May 2021

Contractor Personnel on Site:

1. Brian Davis
2. _____
3. _____

4. _____
5. _____
6. _____

Service Calls – Service Call Number and Description


1. WD# 14170 - 30498 : VFD not controlling H200-1. Reset H200
2. WD# 14058 - York Chiller not running - Last chiller had bad sensor
3. WD# 14160 - LPZ surge protection - needs to be replaced
4. WD# 13311 - 2ND Floor VFR's code 204. Added 2 lbs of 2410 Checked good.

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Brian Davis


Date: 24 May 2021

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Charles Ankney /CET Date: 24 May 2021

Signed: 

E-Mail: charles.c.ankney.mil@mail.mil

45.9 Hz
2.1 A
7.5 A

