

**CERTIFICATION OF WORK  
SERVICE CALL**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: USARC VA050 Date of Visit: 6-22-21

Contractor Personnel on Site:

1. Joshua Carty 4. \_\_\_\_\_
2. \_\_\_\_\_ 5. \_\_\_\_\_
3. \_\_\_\_\_ 6. \_\_\_\_\_

**Service Call Number**

CSS# \_\_\_\_\_ WO# 14350

**Description of Repairs**

To Replace the Compressor control module on  
Asset #2346 chiller Number Two for the  
Second and Third floors.

---

---

**CERTIFICATION OF WORK**

To be signed by the Contractor:

Print Name: Joshua Carty Date: 6-22-21

Signed: J. Carty


To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: CPT T. Friend Date: 6/21/21

Signed: T. Friend

E-Mail: thessalonica.m.friend.mil@mail.mil



1F7  
1S1  
1S70  
1F44  
1F45