

Additional Funding Request

MD002	CSS# 30785 WO# 14527																			
Description of Repairs	S&S was onsite for WO# 14353 replacing the temp sensor and found the unit is tripping the breaker and will need the flow switch replaced. S&S will then add refrigerant to the system and complete a system check.																			
Diagnosis: Initial Work Order	Chiller flow switch needs replaced																			
Diagnostic Fee	\$ 0																			
Additional Labor Cost to Perform Repairs	<p>\$ 800</p> <p>Labor \$100/hr x 8</p>																			
Additional Material Cost to Perform Repairs	<p>\$ 675.92</p> <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 50%;">1" flow switch</td> <td style="width: 10%;">1</td> <td style="width: 15%;">301.93</td> <td style="width: 15%;">301.93</td> </tr> <tr> <td>R410A</td> <td>1</td> <td>323.99</td> <td>323.99</td> </tr> <tr> <td>Shipping</td> <td>1</td> <td>50.00</td> <td>50.00</td> </tr> <tr> <td></td> <td></td> <td></td> <td></td> </tr> </table>				1" flow switch	1	301.93	301.93	R410A	1	323.99	323.99	Shipping	1	50.00	50.00				
1" flow switch	1	301.93	301.93																	
R410A	1	323.99	323.99																	
Shipping	1	50.00	50.00																	
Total Cost of Repair	\$ 1475.92																			



CUSTOMER QUOTATION NO. 647

Tidewater, Inc.
Tidewater, Inc
6625 Selnick Dr.
Suite A
Elkridge MD 21075

Quote Name: NEW
Quote No: 647
Site: MD002 Ordnance Road
Site Contact:
Salesperson: Lindsay Ruby
Created Date: 06/25/2021
Valid For: 30 Day(s)

S&S was onsite for WO# 14353 replacing the temp sensor and found the unit is tripping the breaker and will need the flow switch replaced. S&S will then add refrigerant to the system and complete a system check.

Refrigerant pricing is only good for 24 hours

Service

Item	Quantity	Unit Price	Total
1" Flow Switch	1.00	\$301.93	\$301.93
R410a	1.00	\$323.99	\$323.99
Shipping	1.00	\$50.00	\$50.00
HVAC Labor Rate	8	\$100.00	\$800.00
		Sub-Total ex Tax	\$1,475.92
		Tax	\$0.00
		Total inc Tax	\$1,475.92

Labor	\$800.00
Materials	\$675.92
Sub-Total ex Tax	\$1,475.92
Tax	\$0.00
Total inc Tax	\$1,475.92



JOHNSTONE ANNAPOLIS
1981 MORELAND PKWY, SUITE 101
ANNAPOLIS, MD 21401
410-280-0101
Fax 410-280-0104

Quotation

EXPIRATION DATE	QUOTE NUMBER
07/02/2021	100-101039226
JOHNSTONE ANNAPOLIS 1981 MORELAND PKWY, SUITE 101 ANNAPOLIS, MD 21401 410-280-0101 Fax 410-280-0104	PAGE NO. 1 of 1

QUOTE TO:

S&S MECHANICAL
4845 SOUTH CRAIN HIGHWAY
UPPER MARLBORO, MD 20772

SHIP TO:

S&S MECHANICAL
4845 SOUTH CRAIN HIGHWAY
UPPER MARLBORO, MD 20772

CUSTOMER NUMBER	CUSTOMER PO NUMBER	JOB NAME / RELEASE NUMBER	SALESPERSON	
14831	MD002 NEW	HOUSE		
WRITER	SHIP VIA	TERMS	SHIP DATE	FREIGHT ALLOWED
Jimmy Schropp - Anna 43	PICK UP	Net 10th Prox	06/25/2021	No
ORDER QTY	DESCRIPTION	UNIT PRICE	EXT PRICE	
1ea	F261MAL-V01C JOHNSON CONTROL FLOWSWITCH 1" * Non Returnable / Non refundable Pn: 201696	251.610/ea	251.61	
1ea	B92-910 R410A-25 REFRIGERANT R410A 25 LBS. HFC BLEND NON-FLAMMABLE DISPOSABLE Pn: 122569	269.990/ea	269.99	

Quotation Valid For 7 Days.

Bid Valid for 7 Days - *Excluding Commodities* 24hrs

Subtotal	521.60
S&H Charges	15.00
Estimated Tax	31.30
Amount Due	567.90