

## CERTIFICATION OF WORK SERVICE CALL

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: Montieth VAD48 Date of Visit: 10/5/2021

Contractor Personnel on Site:

1. Nicholas LoRusso 4. \_\_\_\_\_
2. Chris DeNile 5. \_\_\_\_\_
3. \_\_\_\_\_ 6. \_\_\_\_\_

### Service Call Number

CSS# 30972 WO# 14378

### Description of Repairs

Freed up stuck gate & adjusted glide track so that binding would not occur. Adjusted limit switch blocks and gate stop bolts. Recommened the following: Fireplace (1) Gate Roller Bracket, (1) piece extreme drive track, Ant bait to control infestation, (1) Photoeye flood, hydraulic motor service and Cleaning; Change hydraulic fluid, clean gate operator etc.

## CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Nicholas LoRusso Date: 10/5/2021

Signed: Nicholas LoRusso

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: \_\_\_\_\_ Date: \_\_\_\_\_

Signed: NO one available at the time

E-Mail: OF departure







U.S.  
PROPERTY  
NO  
TRESPASS

