

**Additional Funding Request**  
**INVOICE**

<b>VA048</b>	<b>CSS# 31360 WO# 14528 Asset# NA</b>			
Description of Repairs	Diagnosed unit and found low voltage short inside condenser unit from factory. Short caused fuse to blow on control board and burned up transformer. Repaired wire and replaced fuse and transformer.			
Diagnosis: Initial Work Order	AC in office area is not working again. Maybe a power issue			
Diagnostic Fee	\$ 0			
Additional Labor Cost to Perform Repairs	\$ 480 TWI Labor \$80/hr x 6			
Additional Cost	\$ 0 N/A      1			
Total Cost of Repair	\$ 480			

**CERTIFICATION OF WORK  
SERVICE CALL**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: VA099-01 & VA099-02 Date of Visit: 06-29-21- 06-30-21

Contractor Personnel on Site:

1. <u>Will Schultz</u>	4. _____
2. _____	5. _____
3. _____	6. _____

**Service Call Number**

CSS# 31360 WO# 14528

**Description of Repairs**

Diagnosed unit and found low voltage short inside condenser unit from factory.

Short caused fuse to blow on control board and burned up transformer.

Repaired wire and replaced fuse and transformer. Unit working properly.

---

---

**CERTIFICATION OF WORK**

To be signed by the Contractor:

Print Name: Will Schultz Date: 06-30-21

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Christina Winfield Date: 06-30-21

Signed: 

E-Mail: christina.m.winfield.civ@mail.mil

