

**CERTIFICATION OF WORK
SERVICE CALL**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: DE007 B-1 Date of Visit: 06/30/21

Contractor Personnel on Site:

- | | |
|----------------------|----------|
| 1. <u>John Brown</u> | 4. _____ |
| 2. _____ | 5. _____ |
| 3. _____ | 6. _____ |

Service Call Number

CSS# 31393 WO# 14532

Description of Repairs

the noise is coming from one of the fans on the end of the unit.
bearings are starting to go bad. but still operating fine

CERTIFICATION OF WORK

To be signed by the Contractor:


Print Name: Johnny W Brown Date: 06/30/21

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Gabriel Corti Date: 06/30/21

Signed: 

E-Mail: _____

