

CERTIFICATION OF WORK
(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: MD019 Date of Visit: 2/22/2022

Contractor Personnel on Site:

1. B. Davis
2. _____
3. _____
4. _____
5. _____
6. _____

Service Calls – Service Call Number and Description

1. Replaced boiler burner control
2. _____
3. _____

WO #: 16405 CSS #: 32405

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: BRIAN DAVIS Date: 2/22/2022

Signed: B. Davis

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: See Wm Smith Date: 22 FEB 22

Signed: Wm Smith

E-Mail: _____

Gas Fired
Use Combustion Boiler

Gas: Natural Propane

Model No.

National Board No.

ELW-100

ELW-100

BTU Input/Hr. 50K Min. BTU Output/Hr. 15K

BTU Input/Hr. 50K Max. BTU Output/Hr. 75K

Max. Pressure 300 PSI

Pounds/Inch

Maximum Relief Valve Capacity:

Inches W.C.

Boiler Gas Pressure:

Maximum Gas Supply Pressure: 14 inches W.C.

Maximum Permissible Gas Supply Pressure for Purpose of Adjustment:

7 inches W.C. 11 inches W.C.

Adjustment: 7 inches W.C. 11 inches W.C.

Electrical Ratings: 120 V/60 Hz/Two Phase 10 Amps

Pressure Steam and Water

PSI 225.13

Pressure Steam and Water

PSI 225.13



INSPECTED
BY NCR
DATE 2-22-07
1992-

Fulton

BURNER CONTROL

PURGE 00:02
IFlame Signal 0.00

↓ ↑ BACK ← →
EDIT - + + - ENTER - +

POWER
DLOWER
FLAME
MAN
ALARM
REFL

