

**CERTIFICATION OF WORK
SERVICE CALL**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: VA006

Date of Visit: 10/14/21

Contractor Personnel on Site:

1. KEVIN MEADOWS

4. _____

2. _____

5. _____

3. _____

6. _____

Service Call Number

CSS# 15131 **32604** WO# 15131

Description of Repairs

REPLACED RELEIF VALVE ON BOILER2

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: KEVIN MEADOWS

Date: 10/14/21

Signed: Kevin Meadows

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Capt Michael A. Geran

Date: 10/14/21

Signed: [Signature]

E-Mail: michael.a.geran@us.af.mil

OG7543.50

CHAMBER REGISTRATION NO.

ASME

925,000

PERMANENT RATING

SET 30 PSI

SIZE 3/4 IN

NO. 740

MODEL M1

NO. 7543.50