

**CERTIFICATION OF WORK
SERVICE CALL**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: VA 099 Date of Visit: 12/08/2021

Contractor Personnel on Site:

- | | |
|------------------------|----------|
| 1. <u>Howard Floyd</u> | 4. _____ |
| 2. _____ | 5. _____ |
| 3. _____ | 6. _____ |

Service Call Number **CSS 33340 WO 15407**

CSS# 15407 WO# COMØ166889

Description of Repairs

Previous 'spring coupling', removed by Tidewater tech for replacement on HWB-2. Installed a new spring coupling on HWB-1, hot water circulator pump. Remounted the motor, checked operation. **THIS REPAIR IS COMPLETE.**

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Howard Floyd Date: 12/08/2021

Signed: Howard Floyd

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Ben Parrish, POC Date: 12/08/2021

Signed: BP

E-Mail: benjamin.j.parrish.civ@army.mil