

**CERTIFICATION OF WORK
SERVICE CALL**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: VA099 Date of Visit: 12/08/2021

Contractor Personnel on Site:

- | | |
|------------------------|----------|
| 1. <u>Howard Floyd</u> | 4. _____ |
| 2. _____ | 5. _____ |
| 3. _____ | 6. _____ |

Service Call Number **CSS 33341 WO 15408 VA099**

CSS# 15408 WO# COMD166890

Description of Repairs

Set up at HW-1, removed panels and 'User Interface Control' panel. Removed and replaced the defective controller (would not adjust temps). Reassembled all panels and started HW-1 to confirm operational function of the controller.

THIS WORK IS COMPLETE.

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Howard Floyd Date: 12/08/2021

Signed: *Howard Floyd*

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Ben Parrish, POC Date: 12/08/2021

Signed: *B. Parrish*

E-Mail: *benjamin.j.parrish.civ@army.mil*