

**CERTIFICATION OF WORK
SERVICE CALL**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: VA701

Date of Visit: 11-18-21

Contractor Personnel on Site:

- | | |
|----------------------|----------|
| 1. <u>Jacob Long</u> | 4. _____ |
| 2. _____ | 5. _____ |
| 3. _____ | 6. _____ |

Service Call Number

CSS# 33426 WO# 15415

Description of Repairs

Repaired Boiler burner control for faulty ignition

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Jacob Long Date: 11-18-21

Signed: [Signature]

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Terry Casey / SFC Date: 18 NOV 2021


Signed: [Signature]

E-Mail: terry.l.casey.mil@army.mil

US Army Reserve Center - Fort Story Suffolk, Virginia Hot Water System

Home

Parameters



ALERTON

8:12 AM
11/14/2021

AOC