

CERTIFICATION OF WORK  
(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: MD002 Date of Visit: 4/7/2022

Contractor Personnel on Site:

1. B. Davis
2. \_\_\_\_\_
3. \_\_\_\_\_
4. \_\_\_\_\_
5. \_\_\_\_\_
6. \_\_\_\_\_

Service Calls – Service Call Number and Description

1. HRU #1 heat valve not working - new JASE installed
2. by others and all systems in Building #1 functioning
3. \_\_\_\_\_

WO # 16775 CSS # 34763

---

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: BRIAN DAVIS Date: 4/7/2022

Signed: B. Davis

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Laura Key Date: 4/7/27

Signed: Laura Key

E-Mail: \_\_\_\_\_

Honeywell

ML7426B3012

24V 60Hz 12VA Class 2  
0 or 2 to 10VDC Selectable  
135 LBF 3/4" Stroke 1.5min  
SR - Reverse Acting

UL US LISTED 1R7

TEMPERATURE INDICATING  
AND REGULATING EQUIPMENT  
Honeywell GmbH  
Boedbliniger Strasse 17  
71101 Schonebach, Germany

CE 1902  
  


Made in Hungary

<http://ecc.eema.honeywell.com>

71101 Schonebach, Germany

Boedbliniger Strasse 17

Honeywell GmbH

Boedbliniger Strasse 17

Honeywell Hungary