

CERTIFICATION OF WORK
(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: MD002 Date of Visit: APRIL 5, 2022

Contractor Personnel on Site:

1. CHRIS
2. _____
3. _____
4. _____
5. _____
6. _____

Service Calls – Service Call Number and Description


1. INVESTIGATE HOT WATER ON 2ND FLOOR; FOUND THE MIXING
2. VALVES IN THE RESTROOMS NEEDED TO BE ADJUSTED
3. _____

WO # 16918 CSS # 35259

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: CHRIS TROTTER Date: 4/5/2022

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: _____ Date: _____

Signed: Dly Shattrese Frisby

E-Mail: _____

DOMESTIC COLD WATER




DOMESTIC HOT WATER





P-1



DESIGNED IN U.S.A.



**BELL &
GOSSETT
CIRCULATOR**

NBF-33 103351LF 1J01

115V 60HZ 1Ø CLASS F 1.1A 125W

MAXIMUM RATING

LIQUID TEMP.

240°F/115°C

PRESSURE

150PSI/10BAR

IMPEDANCE PROTECTED **LEO-F**

ENC.2



LISTED
96HO



WATER CIRCULATING PUMP

ITT

Made in China

P83032



