

## **CERTIFICATION OF WORK SERVICE CALL**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: NY013 BLDG1 Date of Visit: 6/7/22

#### Contractor Personnel on Site:

1. <u>Patrick Brown</u>	4. _____
2. _____	5. _____
3. _____	6. _____

## Service Call Number

css# 407 wo# 17211

## Description of Repairs

I replaced the water regulator and bypass valves y strainer and piping , I also replaced 6 air vents and tested for proper operation

## **CERTIFICATION OF WORK**

To be signed by the Contractor:

Print Name: Patrick Brown Date: 6/7/22

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: **RON VOGT** Date: **6/7/22**

Signed: Red Vat AFOS

E-Mail:

