

Facility Repair Proposal

Region: 4A
Fac ID: PA027
Date: 11/29/22

CSS # 90785
Maximo Work Order No.: 11473

Asset ID: NA

Original Work Request: Replace the burner tube unit for boiler #1

Description of Repairs Needed:

Labor and material to a.) replace the burner on Boiler 1 at USARC

Parts List:

1 - Spark Electrode (73550P-058)
1 - Flame Rectification Probe (7350P-049)
1 - Burner (7250P-502)

Equipment List: NA

PM History:
NA

Cost Proposal:
See attached RS Means Estimate.

Total Cost: \$2327.38

Estimate Name: CSS 90785 - WO 11473 - PA027 Replace the Burner Tube Unit for Boiler 1

ESTIMATE INFORMATION

Client Name: 99th
Estimate Address: 950 New Castle Rd, Farrell, PA 16121
Type: Unit
Measurement System: US Standard
Notes:

COST DATA

Estimate Summary:						Catalog: Facilities and Commercial Renovation	
						Format: MasterFormat 2018	
						Release: Year 2022 Quarter 4	
						Labor Type: Repair & Remodeling	
						City Cost Index: PENNSYLVANIA / NEW CASTLE (161)	