

**CERTIFICATION OF WORK
SERVICE CALL**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: USARC VA 701 Date of Visit: 06/3/22

Contractor Personnel on Site:

1. <u>Tyrell Griffin</u>	4. _____
2. _____	5. _____
3. _____	6. _____

Service Call Number

CSS# 911 WO# 17795


Description of Repair

Evap. Pressure low, which indicates possible leak.
Will need to perform a leak search and repair.

CERTIFICATION OF WORK

To be signed by the Contractor:


Print Name: Tyrell Griffin Date: 06/3/22

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: SFC Terry Casey Date: 03 JUNE 2022

Signed: 

E-Mail: terry.l.casey.mil@army.mil

Leak













