

**CERTIFICATION OF WORK
SERVICE CALL**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: WV029-02 Date of Visit: Jan 13, 2023

Contractor Personnel on Site:

- | | |
|------------------------|----------|
| 1. <u>Ricky Barker</u> | 4. _____ |
| 2. _____ | 5. _____ |
| 3. _____ | 6. _____ |

Service Call Number

CSS# 91356 WO# 11820

Description of Repairs

Replaced bad inducer motor on ray vac tube
heater in wasbay

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Richard A. Barker Date: Jan 13, 2023

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Adam Romesburg/GS9 Date: Jan 13, 2023

Signed: 

E-Mail: adam.c.romesburg.mil@army.mil



