

Additional Funding Request

Submitted: 06/07/2022

VA701	CSS 917 WO 17798								
Description of Repairs	Moore's is proposing to run new communication wire from the condenser to the evaporator. Start, test and ensure proper unit operations. If any other major parts needed will have to be submitted under a separate proposal for your approval.								
Original SC Investigative Diagnosis	\$480								
Diagnosis: Initial Work Order	Mini split 1 not working *Note: Wire shortage between the evaporator and condensate line.								
Explanation of Additional Costs for Repairs	N/A								
Additional Material Cost to Perform Repairs	<p>Materials: \$ 180.05</p> <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="text-align: left; padding: 2px;">ITEM</th><th style="text-align: left; padding: 2px;">QUANTITY</th><th style="text-align: left; padding: 2px;">UNIT PRICE</th><th style="text-align: left; padding: 2px;">TOTAL</th></tr> </thead> <tbody> <tr> <td style="text-align: left; padding: 2px;">Materials (See attached detail)</td><td style="text-align: left; padding: 2px;">1</td><td style="text-align: left; padding: 2px;">180.05</td><td style="text-align: left; padding: 2px;">180.05</td></tr> </tbody> </table>	ITEM	QUANTITY	UNIT PRICE	TOTAL	Materials (See attached detail)	1	180.05	180.05
ITEM	QUANTITY	UNIT PRICE	TOTAL						
Materials (See attached detail)	1	180.05	180.05						
Additional Labor Cost to Perform Repairs	<p>Labor: \$720 6 hours each/ \$120</p>								
Total Cost of Repair	\$1380.05								



P.O. Box 119 • Altavista, VA 24517 • 24 Hour Service: 800.789.7199 • Fax: 888.722.2712 • MooresElectric.com

Proposal

June 7, 2022

Quotes are valid for 14 days.

USARC - VA701
886 Carolina Rd.
Suffolk, VA 23345
Email

adam.colopy@tideh2o.net & Mary.Lowery@tideh2o.net

Contact Name Mary Lowery & Adam Colopy
Telephone 0.00
Cell Phone 614-623-9569
WO # CSS 917 WO 17798

DESCRIPTION OF EQUIPMENT:

Server Room
Make: Mitsubishi
Model: PUZ-A24NHA7
Serial: 74U02254C

DESCRIPTION OF PROBLEM:

Technician checked in with Casey. POC stated the unit would trip breaker when trying to run system and would cause fuses to blow. Technicians access the condensing unit. Found disconnect was off. Confirmed power at disconnect. Power present. Accessed head located in next room over. Found that no power was on the head coming from communication wires. Also note that comm wires are routed inside the same conduit as line voltage. This is a problem because the line voltage interferes with communication on comm wires. Will need to run new separate communication wire from condenser to evaporator. Will submit quote. Once system is wired separately, further troubleshooting may be required.

DESCRIPTION OF REPAIRS:

Moore's is proposing to run new communication wire from the condenser to the evaporator. Start, test and ensure proper unit operations. If any other major parts needed will have to be submitted under a separate proposal for your approval.

MATERIAL, EQUIP OR PARTS

	Quantity		Sell price
Comm. Wire	1.00	\$	100.05
Tax	1.00	\$	5.00
Fuel Surcharge	1.00	\$	20.00
Truck Fee	1.00	\$	55.00
		Material Total	\$ 180.05

LABOR ITEMIZED

			Labor
Labor - Incurred	4	\$ 120.00	\$ 480.00
Labor - One Man	6	\$ 120.00	\$ 720.00
		Labor Total	\$ 1,200.00

Thank you for your business. If you have any questions or concerns, please feel free to contact us via telephone or quotes@mooreselectric.com

Materials \$ 180.05
Labor \$ 1,200.00

Adam Barker, Parts and Estimating Manager 434-309-2474	TOTAL	\$ 1,380.05
Gordon Yowell, Changeout Estimator 434-309-2497		
Robert Lowery, Changeout Estimator 434-309-2589		
James Davis, Estimator 434-309-2568		
Marvin Slaughter, Estimator 434-369-3514		

Approved by: _____

In consideration of Moore's Electrical & Mechanical extending credit to the above applicant, the undersigned hereby guarantees unconditionally and irrevocably. The compliance of all terms of the application and agreement, including the payment of any sums within the net terms agreed upon between the customer and Moore's, plus any additional costs such as a 1.5% monthly interest charge starting once an invoice becomes 30 days past due, service charges, legal fees and any means taken in order to collect debt. If it is deemed necessary to litigate, it is agreed that the County or District Court of Campbell County, Virginia shall be the venue of any suit. This guarantee shall remain in full force unless and until notice in writing is sent certified mail and received by Moore's Electrical & Mechanical. Said notice cannot be within 14 days of this signed agreement.

QUOTATION

AMERICAN REFRIGERATION SUPPLIES,
INC.
4605 E. Princess Anne Road
Norfolk, VA 23502
US
757-853-7441



AMERICAN REFRIGERATION SUPPLIES, INC.

Order Number	
10197890	
Order Date	Page
06/07/2022 06:50:21	1 of 1

Quote Expires On: 07/07/2022

Bill To:

MOORE'S ELECTRICAL& MECHANICAL
P O BOX 119
ALTAVISTA, VA 24517

Ship To:

MOORE'S ELECTRICAL& MECHANICAL
P O BOX 119
ALTAVISTA, VA 24517

4343694374

Requested By: MARVIN SLAUGHTER

Customer ID: 20802

PO Number					Ship Route	Taker		
						CHRISTOPHER.LINSCOTT		
Quantities			Item ID Item Description Primary Bin Location			Pricing UOM Unit Size	Unit Price	Extended Price
Ordered	Allocated	Remaining	UOM Unit Size	Disp.				
1	0	1	EA		58340803	EA	83.376	83.38
		1.0			WIRE MINI SPLIT 14 GA 4 STRAND 50 CORRA 0217006000		1.0	

Total Lines: 1

SUB-TOTAL:	83.38
TAX:	5.00
AMOUNT DUE:	88.38
<i>U.S. Dollars</i>	