

# WORK ORDER

**Date:** 07-10-2023  
**Work Order #:** 88006  
**Tech:** Anthony Caldwell  
**Job:** (Q) FA/FS Service Quotes  
**Customer:** CMI Management, Inc.  
**Phone:** (703) 738-5305  
**Address:** 103 Lakeview Dr Cross Lanes, WV 25313  
**Payment Type:**  
**Amount Paid:** 0.00  
**Check #:** 0  
**Request:** Quote 7239 \$1,740.00 Contact Reginald Cook 703-738-5307 1  
- A17492 Ansul Cartridge 101-20 1 - Ansul SS 3 Gal Tank  
(Hydr/Refill) 1 - Labor to Deliver and Install

## Work Completed

Installed all new quoted parts and completed the inspection as requested.

## Material

Inventory Item	Description	Quantity	Price	Amount
(MATERIAL-FA) MATERIAL-FA	3gal ansul kitchen tank	1.0		
(MATERIAL-FA) MATERIAL-FA	3gal Ansulex	1.0		
(EXT-LINK 360) EXT-LINK 360	Model K Link, 360 deg F	3.		
(MATERIAL-FA) MATERIAL-FA	ansul 101-20 p#-17492	1.0		

## Labor

Labor Item	Description	Hours	Price	Amount
(LABOR-ALARM-REG) Alarm Service Labor-Regular	Alarm Service Labor-Regular	4.00		

## Customer Signature

Reginald Cook

## Tech Signature

Anthony Caldwell

