

CASTO TECHNICAL SERVICES, INC.

SERVICE REPORT

DATE ARRIVAL TIME 10:35 pm DEPARTURE TIME JOB/TCK NO 194836

CUSTOMER PO. NO. CSS# 92285 WO# 12334

JOB NAME/LOCATION *USARC - South Ridge*

SERVICE REQUESTED monitoring on the Trane Chiller (M# CGAM080; S# U15B47125).

Manufacture: _____
Model#: _____
Serial#: _____
Refrigerant Added: Qty lb oz TYPE
Refrigerant Removed: Qty lb oz TYPE

- Leak Tested
- Leak Found
- Leak Repaired

Method: _____

Total Charge: _____

WORK PERFORMED/UNIT INFO

worked, re wired the controller. Checked unit operations and the unit came on shut the unit back down to replace the sensors. The screen would not turn back on and found that i blew the 3 amp glass fuse, Lewis went and picked up some new ones. Turned the unit back on and started checking the unit operations. Water supply temperature started dropping. Updated the customer and went through and made sure all the ahu's were running. Talked with the customer about putting together a labor only quote to have the control settings gone through and verified. Picked up and checked out with the customer.

NATURE OF WORK

Regular Service _____

Quoted Service _____

Start-up/Warranty _____

SPD _____

Contract Service _____

Energy Management _____

PARTS, MATERIALS AND SUBCONTRACTED SERVICES

SUMMARY OF TIME

JOB COMPLETE

YES _____ NO _____ EXPLAIN _____

SIGNATURE _____

Customer Representative