

## CERTIFICATION OF WORK SERVICE CALL

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: Wv020-01 Date of Visit: 11-18-22

Contractor Personnel on Site:

1. <u>Ricky Barker</u>	4. _____
2. _____	5. _____
3. _____	6. _____

**Service Call Number**

CSS# 90664 WO# 11467

**Description of Repairs**

Found circulating pump turned off. Restored power and oiled motor. Pump motor running as it should be upon departure.

---

---

---

## CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Richard A Barker Date: 11-18-22

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Jennifer Bailie Date: 11-18-22

Signed: 

E-Mail: jennifer.a.bailie.ctr@army.mil

Boiler 1