

**CERTIFICATION OF WORK
SERVICE CALL**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: NY051 BLDG1 Date of Visit: 8/20/20

Contractor Personnel on Site:

1. <u>Patrick Brown</u>	4. _____
2. _____	5. _____
3. _____	6. _____

Service Call Number

CSS# TBD WO# 10230


Description of Repairs

I found the Janitor's Closet sink valves opened allowing the hot water to over pressure the cold water filling the cold water system with hot water

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Patrick Brown Date: 8/20/20

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: SFC PATRIC HANLON Date: 8/20/20

Signed: 

E-Mail: _____

