

Date: 11/8/2023

Region: 4A
FAC ID: NY052

CSS No.: 95058
Maximo WO No.: 14063



Asset #: NA

Priority: Routine

Original Work Request:

Rpr Boilers 1 and 2. Boiler 1 Make: Lochinvar Model: FTX600N Serial: 1846112582922 e. Reason for declining certification: Install stop valve as required by NBIC Part 1 Section 3.5.7.1. Excessive debris observed on firesides, Clean firesides ASAP. Boiler 2 Make: Lochinvar Model: FTX600N Serial: 184611582919 e. Reason for declining certification: Install stop valve as required by NBIC Part 1 Section 3.7.5.1 (b). Excessive debris observed on firesides, Clean firesides ASAP

Description of Repairs Needed:

Labor and material to a.) install 2 new stop valves and clean boilers.

Labor:

	Labor Hrs	Labor Rate	Total
Technician	24	\$ 128.00	\$ 3,072.00
Trip Charge	1	\$ 150.00	\$ 150.00

Material List:

	Quantity	Cost	Total
Stop Valves	2	\$ 409.00	\$ 818.00
			\$ -
			\$ -

Equipment List:

	Quantity	Cost	Total
			\$ -
			\$ -
			\$ -

PM WO History:

NA

Estimate Summary:

Labor	Material	Equipment
\$ 3,222.00	\$ 818.00	\$0.00

Sub Total	G&A 12%	Fee 6%	Total Estimate
\$4,040.00	\$484.80	\$242.40	\$4,767.20



November 8, 2023

Tidewater
US Army Corps of Engineers
198 Cornwall St.
Penn Yan, NY 14527

Attn: Karlee Demain

Re: Install isolation valves and clean boilers

Ms. Demain,

Postler & Jaeckle Service is pleased to provide a quote for labor and materials to install 2 new stop valves and clean boilers per your request. Your cost for this service will be \$128/hr. x 24 = \$3,072.00 for labor, 409.00 x 2= \$818.00 for stop valves, and \$150.00 truck charges for a total of \$4,040.00 plus any applicable taxes. This quote is based on work being performed during normal working hours of 8:00am to 4:30pm Monday through Friday. Thank you for the opportunity to provide this quote for your facility. Please contact me with any questions.

Sincerely,

DAVE HENDEE
Field Sales Support
Postler & Jaeckle Corp.
2000 Lake Rd., Elmira, NY 14903
T 607-739-8303 | C 607-215-6523
E: dhendee@postler.com