

Date: 7/30/2024

Region: 4C

CSS No.: 98122

FAC ID: WV029

Maximo WO No.: 15823

Asset #: NA

Priority: Emergency



**Original Work Request:**

Repair fire alarm. Walked in this morning to alarms chirping in both buildings - constantly like every 3 minutes. Alarms reading the following: VoIP module - hardware missing; Ring Port PO - Ring Port Trouble and in the Motor Pool: Motor Pool Panel 1 - Connection Trouble and the same Ring Port issue in that building also. Cannot reset these alarms. They aren't calling the fire department, but we need to see what's causing the issue.

**Description of Repairs Needed:**

Labor and material to a.) performed temporary fix on the voice board, b.) replace (1) voice board card for the fire panel, c.) replace (1) speaker strobe that was broken, d.) upgrade the software in the panels.

Labor:	Labor Hrs	Labor Rate	Total
Technician	7	\$ 250.00	\$ 1,750.00
			\$ -

Material List:	Quantity	Cost	Total
Voice Board	1	\$ 199.02	\$ 199.02
Speaker strobe	1	\$ 100.98	\$ 100.98
		\$ -	\$ -
		\$ -	\$ -

Equipment List:	Quantity	Cost	Total
		\$ -	\$ -
		\$ -	\$ -
		\$ -	\$ -

**PM WO History:**

NA


**Estimate Summary:**

Labor	Material	Equipment
\$ 1,750.00	\$ 300.00	\$ 0.00

Sub Total	G&A 12%	Fee 6%	Total Estimate
\$ 2,050.00	\$ 246.00	\$ 123.00	\$ 2,419.00

INVOICE

96761-FA



**Bill to:** Morgantown USARC  
 228 Comfort Inn Rd  
 EMAIL INVOICES!  
 Morgantown, WV 26505  
 (824) 544-5252  
 Customer ID: MORUSARC

**Site:** Morgantown USARC  
 228 Comfort Inn Rd  
 EMAIL INVOICES!  
 Morgantown, WV 26505  
 (824) 544-5252  
 Site ID: MORUSARC

TECHNICIAN	WORK ORDER NO.	PURCHASE ORDER NO.	FEIN	INVOICE NO.	INVOICE DATE	PAYMENT TERMS	DUE DATE
Hunter Mouse	96761		55-0334215	96761-FA	7/22/2024	Net 30	8/21/2024
<b>Work Ordered by:</b> Jennifer Bailey							

Page 1 of 1

**DESCRIPTION:** Contact Jennifer Bailey 724-544-5252

NOT TO EXCEED \$2,050.00

ECALL - WV029 WO15823 CSS98122 Repair fire alarm. Walked in this morning to alarms chirping in both buildings - constantly like every 3 minutes. Alarms reading the following: VoIP module - hardware missing; Ring Port PO - Ring Port Trouble and in the Motor Pool: Motor Pool Panel 1 - Connection Trouble and the same Ring Port issue in that building also. Cannot reset these alarms. They aren't calling the fire department, but we need to see what's causing the issue.

QTY	ITEM #	DESCRIPTION		UNIT PRICE	EXTENDED TOTAL
1		Quoted	*	2050.00	2,050.00

*We accept credit card payments by phone!*

**304-760-5723**

*Or use this link to pay:*

<http://www.gobillandpay.com/brewer>

*Thank you for your business!*

*If paying by check, please include invoice number(s) on remittance advice or return top portion of the invoice with payment for proper allocation.*

SUBTOTAL	2,050.00
SALES TAX	0.00
<b>TOTAL</b>	<b>\$ 2,050.00</b>

\* Indicates item is non-taxable