

CASTO TECHNICAL SERVICES, INC.

## SERVICE REPORT

DATE 2024 7 24 ARRIVAL TIME 8:00

DEPARTURE TIME 11:00

JOB/TICK NO 211004

CUSTOMER PO. NO. WO#16367/CSS98597

JOB NAME/LOCATION USARC - Cross Lanes WV006

**SERVICE REQUESTED** The air compressors in the AMSA are not running keep tripping breaker. Air compressors are detrimental to AMSA

Manufacture: _____				
Model#: _____				
Serial#: _____				
<b>Refrigerant Added:</b>	Qty	lb	oz	TYPE
<b>Refrigerant Removed:</b>	Qty	lb	oz	TYPE

- Leak Tested**
- Leak Found**
- Leak Repaired**

**Method:** \_\_\_\_\_

**Total Charge:** \_\_\_\_\_

**WORK PERFORMED/UNIT INFO**

On arrival made contact with customer. He led us to the compressor and we began diagnosis. Found a burnt wire and bad wire nut connection. Changed wire nut and applied power. Unit tripped breaker again after running for 3 minutes. Found that breaker was 35 amps and needed to be 50 in order to run both 25 amp compressors. Spoke with customer to figure out the solution he wanted to make. He said that for now he would like us to put a sign on it to only one one compressor at a time since one compressor would only pull 25 amps and was within limits for the breaker. He asked us to put together a quote for what it would cost to put in for wiring changes and a new phase monitor.

**NATURE OF WORK**

Regular Service \_\_\_\_\_

Quoted Service \_\_\_\_\_

Start-up/Warranty \_\_\_\_\_

SPD \_\_\_\_\_

Contract Service \_\_\_\_\_

Energy Management \_\_\_\_\_

**PARTS, MATERIALS AND SUBCONTRACTED SERVICES**

## **SUMMARY OF TIME**

**JOB COMPLETE**

YES  NO  EXPLAIN

**SIGNATURE** \_\_\_\_\_

### **Customer Representative**