

CERTIFICATION OF WORK

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: VA039 Date of Visit: 3/11/25

Contractor Personnel on Site:

1. Aaron Skeens



Work Performed:

Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. WO18074 WO18155 WO18156 WO18157 WO18176 MAR PM
WO18224 WO18075 WO18206




CERTIFICATION OF WORK



To be signed by the Contractor:

Print Name: Aaron Skeens Date: 3/11/25


Signed:



To be signed by Facility Manager:

By signing the Certification of Work, I certify that the above-named individuals representing the Contractor arrived on site and to the best of my knowledge, completed the stated work listed.


This is NOT a Certification that the Work was performed correctly – The COW simply verifies that that someone representing the Contractor was onsite and accomplished something



Print Name/Rank: Gregory Rasnick Date: 3/11/25

Signed: GR

E-Mail: _____



All FE at VA039 check out well with no issues.

Circulating pumps check out with no issues.

Expansion tank #1 is no longer in use. McQuay minisplit cassette unit #4645 is shut off due to leaking shut off valve.

McQuay #4638 checks out with no issues. McQuayy mini split #5101 has been replaced by Blueridge Mini Split.

Buidling controls check out well with no alarms or issues. Replacement of mini split units in building 2 is recommended.

Thermostats quit working and are not cooling properly. Filters are worn out and need replaced. They are non disposable filters that have been cleaned