

CERTIFICATION OF WORK

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: VA039 Date of Visit: 10-MAR-2026

Contractor Personnel on Site:

1. Aaron Skeens
2. _____

Work Performed:

Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. WO21282 WO21378 WO21283 WO21408 MAR PM

Service Calls – Service Call Number and Description

1. CSS# FE #1 - 10 lb FE has been replaced at VA039-01 as well as
2. CSS# FE #3 - K TYPE FE in kitchen. All others check out with no issues.
3. CSS# Asset #4638 Sea Breeze PTAC PM complete. Operating flawlessly.
Asset #4645 McQuay Cassete #1 needs motor replacement. McQuay
#2 operating well with no issues. PM complete. No filter or filter rack.

-AS

CERTIFICATION OF WORK

To be signed by the Contractor:


Print Name: Aaron Skeens Date: 10-MAR-2026

Signed:  _____

To be signed by Facility Manager:

By signing the Certification of Work, I certify that the above-named individuals representing the Contractor arrived on site and to the best of my knowledge, completed the stated work listed. This is **NOT** a Certification that the Work was performed correctly – The COW simply verifies that that someone representing the Contractor was onsite and accomplished something

Print Name/Rank: Gregory Rasnick Date: 10-MAR-2026

Signed:  _____

E-Mail: _____

Asset # 5101 Blueridge Mini Split PM complete with no issues.
Mini Split #1 - Compressor locked and broken display.
Mini Split #2 - Thermostat is not operating correctly and filter is broken.
Both mini splits are not operating correctly and needs replaced.

-AS

