

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
ROOF DRAINS, DOWNSPOUT, AND GUTTER INSPECTION

SITE AND BLDG #: VA012

MECHANIC
SIGNATURE: 


DATE: 10/3/24

LOCATION/RM #: WO# 16813 ASSET # GO92

START TIME: 10AM

FINISH TIME: 11AM

CHECK K	CHECKPOINT DESCRIPTION	TASK COMPLET	
		YES	NO
SPECIAL INSTRUCTIONS			
1	Use care when working in high places.	●	
2	Use safety line with harness if necessary.	●	
TO BE PERFORMED AT EACH INSPECT			
1	Check gutters, drains, and downspouts to insure that they are properly attached to the building, connections sealed, and free of debris.	●	
2	Check drain strainers/screens for condition and proper installation.	●	
3	If downspouts have heaters, test, operate and correct deficiencies.		●
4	Remove all trash, debris or unsecured material from roof area and gutters.	●	
5	Where downspouts discharge onto lower roofs, check if there has been any scouring of the surfacing.	●	
6	Check for missing or damaged splash blocks.	●	



Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed discription of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes:

All gutter and roof drains check out well, except one pending repair.
 Waiting on 2 downspouts to finish repairs.
 -AS

