

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST

ROOF DRAINS, DOWNSPOUT, AND GUTTER INSPECTION

SITE AND BLDG #: VA001-01

MECHANIC
SIGNATURE: 

DATE: 2-OCT-2025

LOCATION/RM #: WO# 20251 ASSET # G089

START TIME: 1PM

FINISH TIME: 2PM

CHECK K	CHECKPOINT DESCRIPTION	TASK COMPLETE	
		YES	NO
SPECIAL INSTRUCTION			
1	Use care when working in high places.	●	
2	Use safety line with harness if necessary.	●	
TO BE PERFORMED AT EACH INSPECTION			
1	Check gutters, drains, and downspouts to insure that they are properly attached to the building, connections sealed, and free of debris.	●	
2	Check drain strainers/screens for condition and proper installation.	●	
3	If downspouts have heaters, test, operate and correct deficiencies.		●
4	Remove all trash, debris or unsecured material from roof area and gutters.	●	
5	Where downspouts discharge onto lower roofs, check if there has been any scouring of the surfacing.	●	
6	Check for missing or damaged splash blocks.	●	



Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes:

All FE's at this location check out well with no issues.
One gutter cleared and roof cleaned off
-AS

