

**CERTIFICATION OF WORK
PREVENTIVE MAINTENANCE**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: NY051 Date of Visit: 5/22/23

Contractor Personnel on Site:

- | | |
|-------------------------|----------|
| 1. <u>Patrick Brown</u> | 3. _____ |
| 2. _____ | 4. _____ |

Work Performed:

Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. WO#'S , 21801 , 21824 , 21825 , 21874 , 21907 , 21908 ,
2. 21909 , 21910 , 22070 , 22084 , 22095 , 21875
3. ASSET#'S , 10043 , 10066 , 10069 , IL-36 , 10044 , 10045 ,
4. 10067 , 10068 , 10037 , IL-37 , 190917-, 294 , 299 , 280 ,
5. 281 , 282 , 283 , 284 , 295 , 296 ,

CERTIFICATION OF WORK

To be signed by the Contractor:


Print Name: Patrick Brown Date: 5/22/23

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:


Print Name/Rank: SGT Tanner, Shane Date: 5/22/23

Signed: 

E-Mail: _____

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
CHEMICAL BYPASS/POT FEEDER

SITE AND BLDG #: NY051 BLDG1

**MECHANIC
SIGNATURE:** 

DATE: 5/22/23

LOCATION/RM #: mechanical **WO#** 22095 **ASSET #** 190917-283

START TIME: 11:45am

FINISH TIME: 12pm

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
SPECIAL INSTRUCTIONS				
1	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	✓		
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Check physical condition of feeder. Clean and/or repair as needed.	✓		
2	Check valves for proper operation. Ensure no leaks are present and repair as needed.	✓		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed discription of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes: