


PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
CHEMICAL BYPASS/POT FEEDER

SITE AND BLDG #: NY070 BLDG1
boiler room
LOCATION/RM #: WO# 14404 **ASSET #** 4864

**MECHANIC
SIGNATURE:** 

DATE: 12/6/23

START TIME: 9:45am

FINISH TIME: 10am

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		SPECIAL INSTRUCTION
		YES	NO	
1	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	✓		
TO BE PERFORMED AT EACH INSPECTION				
1	Check physical condition of feeder. Clean and/or repair as needed.	✓		
2	Check valves for proper operation. Ensure no leaks are present and repair as needed.	✓		



Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct materials). If any repair identified during PM exceeds \$250, the technician shall open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and description of the repair.

To be performed by: General Maintenance Worker

Additional Notes:

This pot feeder needs to be replaced There's a work order currently opened for this problem