


PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
CHEMICAL BYPASS/POT FEEDER

SITE AND BLDG #: VA001-01

MECHANIC SIGNATURE: 

DATE: 2-SEP-2025

LOCATION/RM #: WO# 19950 ASSET # 9003

START TIME: 11AM

FINISH TIME: 12PM

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS <small>(IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)</small>
		YES	NO	
SPECIAL INSTRUCTIONS				
1	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	●		
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Check physical condition of feeder. Clean and/or repair as needed.	●		
2	Check valves for proper operation. Ensure no leaks are present and repair as needed.	●		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed discription of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes: Pot feeder at VA001 checks out well with no issues
-AS

