



Proudly serving the entire states of Virginia & North Carolina.

Altavista, VA • Charlottesville, VA • Chesapeake, VA • Manassas, VA
Lynchburg, VA • Richmond, VA • Raleigh, NC • Charlotte, NC

P.O. Box 119 • Altavista, VA • 800.789.7199 • service@mooreelectric.com

Billing Address		Site Address	
Customer:	TIDEWATER, INC	Customer:	USARC VA701 SUFFOLK
Address:	6625 SELNICK DRIVE ELKRIDGE MD 21075	Address:	886 CAROLINA ROAD SUFFOLK VA 23345
Phone:	614-623-9569	Phone:	410-688-0142
Service Call #:	COM0179788	Call Type:	COM-TMPM

Service Requested
T&M CHILLER PM
RESCHEDULE TO ENSURE SOMEONE IS ONSITE.

Problems					
Description	Tech	Equip. Desc and Model	Manufacturer	Equip. Serial	Asset ID
TIME AND MATERIAL PM	ALANBOLING				

Tech Notes
Tech: ALAN BOLING, Date: 5/23/22 - Arrived on site- work order didn't state what time of appointment. Emailed dispatch, CSR Nicole informed me it was for 9am. Due to already on site(7:30am), went ahead to back of building to chiller. Hooked up hoses and rinsed micro channel coil thoroughly. Looked at control panels. Found C1 and C2 out on evap pressure alarm lo. Mr Will arrived- accessed control computer. Cleared/reset alarms. Space in many rooms were at 78-80 degrees. Reset/cleared alarms at control panel at chiller. Unit went into cooling. About 45minutes- one compressor was out on evap pressure low alarm. Spaces are cooling efficiently at this time. No further issues found. JOB COMPLETE

Labor			
Date	Technician	Description	Hours
5/23/2022	ALAN BOLING	COMMERCIAL TRAVEL TIME	1.00
5/23/2022	ALAN BOLING	REGULAR HVACR LABOR	4.00

Materials			
Date	Part Number	Description	Quantity
No records found			

Signed By	SFC CASEY	Signature		Date	5/23/2022