

**CERTIFICATION OF WORK
PREVENTIVE MAINTENANCE**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: NY051 BLDG1 Date of Visit: 2/8/22

Contractor Personnel on Site:

1. <u>Patrick Brown</u>	3. _____
2. _____	4. _____

Work Performed:

Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. WO#'S , 15904 , 15927 , 15931-15933 , 15960 , 15974 , 15987 , 15988 ,
2. 16009-16012 , 16183 , 16184 , 16241 , 16260 , 16271 , 16272 , 16185
3. ASSET#'S , 10043 , 10051-10054 , 10043 , 10066 , 10069 , 10044 ,
4. 10045 , 10067 , 10068 , 10063 , 10079 , 190917- , 279-284 , 288 , 294 ,
5. 299 , 295 , 296 , 279 , 286 , 301 ,

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Patrick Brown Date: 2/8/22

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: SFC ERIC ABBOTT Date: 2/8/22


Signed: 

E-Mail: _____

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
CIRCULATING AND BOOSTER PUMPS

SITE AND BLDG #: **NY051 BLDG1**

LOCATION/RM #:	Mech room	WO#	16009,	ASSET #	10044
			16010,		10045

MECHANIC
SIGNATURE: 

DATE: **2/8/22**START TIME: **11am**FINISH TIME: **12pm**

CHECK POINT	CHECKPOINT DESCRIPTION	16184 10063	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
			YES	NO	
SPECIAL INSTRUCTIONS					
1	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.		✓	/	
2	It is generally not a good idea to tamper with pumps using mechanical seals if they are otherwise performing properly. Since mechanical seals can cost as much as the pump, it is usually not cost effective to risk damaging the seal by performing an annual internal inspection of the pump.-Report any leaks		✓	/	
TO BE PERFORMED AT EACH INSPECTION SERVICE					
1	Lubricate pump and motor bearings as per manufacturer's specifications. Bearings require lubrication atleast annually.4 shots of grease per PM		✓	/	used Lucas heavy duty grease
2	Inspect couplings and check for any pump seal leaks.		✓	/	no leaks
3	Check motor mounts and vibration pads		✓	/	mounts and pads are good
4	Tighten all pump flanges.		✓	/	flanges are tight
5	Visually check pump alignment and coupling -Report unusual vibration		✓	/	alignment is good no vibration
6	Inspect electrical connections		✓	/	electrical connections are good

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed discription of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes:

Asset# 11786 boiler pump #2 needs to be replaced and there is an open WO on it