

**CERTIFICATION OF WORK
PREVENTIVE MAINTENANCE**

(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: DE001

Date of Visit: 11/20/2020

Contractor Personnel on Site:

1. Abe Patz

3. _____

2. _____

4. _____

Work Performed:

Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. WO 13097 Asset 190918-116

2. _____

3. _____

4. _____

5. _____

CERTIFICATION OF WORK

To be signed by the Contractor:


Print Name: Abe Patz Date: 11/20/2020

Signed: 

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: SPE Jose J. Mijin Date: 11/20/2020

Signed: 

E-Mail: _____

Tidewater, INC
 DE-001
 344 North New Street
 Dover DE 19904
 (410) 540-8700

Recorded By: Jon Miller
 (301) 580-9820
 jmiller@bondwater.com

Boiler Room - HVAC Equipment

Test	Hot Loop			
Conductivity (as mmhos)	1100 3500 max			
pH	8.0 8 - 10.5			
Molybdate (ppm as Mo)	200 50 min			

Opening Comment

Performed bi-annual scheduled service visit.

Service performed by Abe Patz.

Hot Water Loop

Online 

All readings indicate good levels of protection for closed system.