



# Closed Loop Water Analysis Report

<b>Account Name:</b> CMI – Fleming Godwin		<b>Customer Name:</b> Clinton Bates				
<b>Sample No:</b> 29745	<b>Date Sampled:</b> 5/8/19	<b>Date Received:</b> 5/16/19		<b>Date Completed:</b> 5/31/19		

	Boiler Loop					
Color	Light Yellow w/Sediment					
pH	5.4					
Specific Conductance micromhos, 18°C	1286					
Total Iron as Fe, ppm	129					
Copper as Cu, ppm	0.04					
Sodium Nitrite as NaNO <sub>2</sub> , ppm	N/D					
Molybdenum as Mo, ppm	<0.02					
Glycol Percent by Volume	N/D					
Freeze Point, °F	-----					
Reserve Alkalinity	-----					
Orthophosphate as PO <sub>4</sub> , ppm	-----					

<b>Additional Comments:</b>	

  

<b>N/D = None Detected</b>	<b>----- = Not Tested</b>
----------------------------	---------------------------

Tests Performed By TH

Approved By TB