

Additional Funding Request

Submitted: 10.22.2020

DE001 – pump	CSS #Pending WO#12929								
Description of Repairs	SOW: found boiler #1 circ. Pump not working during PM today . This will need to be addressed to pass boiler cert . Pic Included								
Original SC Investigative Diagnosis	NA								
Diagnosis: Initial Work Order	S&S purposed to install a new recirculation pump.								
Explanation of Additional Costs for Repairs	N/A								
Additional Material Cost to Perform Repairs	<p>Materials: \$917.66</p> <table border="1"> <thead> <tr> <th>ITEM</th><th>QUANTITY</th><th>UNIT PRICE</th><th>TOTAL</th></tr> </thead> <tbody> <tr> <td>Pump</td><td>1</td><td>\$917.66</td><td>\$917.66</td></tr> </tbody> </table>	ITEM	QUANTITY	UNIT PRICE	TOTAL	Pump	1	\$917.66	\$917.66
ITEM	QUANTITY	UNIT PRICE	TOTAL						
Pump	1	\$917.66	\$917.66						
Additional Labor Cost to Perform Repairs	<p>Labor: \$1,400.00 HVAC Labor Tech/14 hours/Rate \$100.00 per hour = \$1,400.00</p>								
Total Cost of Repair	\$2,317.66								