



Closed Loop Water Analysis Report

Account Name: CMI – Cape Henlopen		Customer Name: Clinton Bates				
Sample No: 29744	Date Sampled: 5/8/19	Date Received: 5/16/19		Date Completed: 5/31/19		

	Boiler Loop					
Color	Clear					
pH	8.8					
Specific Conductance micromhos, 18°C	369					
Total Iron as Fe, ppm	0.19					
Copper as Cu, ppm	<0.04					
Sodium Nitrite as NaNO ₂ , ppm	N/D					
Molybdenum as Mo, ppm	9.3					
Glycol Percent by Volume	N/D					
Freeze Point, °F	-----					
Reserve Alkalinity	-----					
Orthophosphate as PO ₄ , ppm	-----					

Additional Comments:

N/D = None Detected ----- = Not Tested

Tests Performed By TH

Approved By TB