

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST

SITE AND BLDG #: DE007 B-1

LOCATION/RM #: WO# 18723

MECHANIC SIGNATURE: John W. B. DATE: 08/17/22

START TIME: 0900 FINISH TIME: 1630

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Check, clean, and/or replace filters as required.	/ / /		
2	Initial and Date Filter (if disposable)			
3	Initial and Date Yellow Maintenance Tag (if applicable)			
ASSET #	SIZE	QTY		NOTES/ ACTIONS
	Record Size :			
190918-138	Washable filter	1		
	NOTE : Any AHU with outside air -Filter gets replaced Quarterly			
	All other filters get replaced annually But inspected Quarterly			

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Technician

Additional Notes: