

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
AIR CURTAIN

SITE AND BLDG #: **DE007 B-4**MECHANIC
SIGNATURE: DATE: **06/06/22**LOCATION/RM #: **WO# 17721 ASSET # QY4-213**START TIME: **0900**FINISH TIME: **1630**

| CHECK POINT | CHECKPOINT DESCRIPTION | TASK COMPLETE | | NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION) |
|---|---|---------------|----|---|
| | | YES | NO | |
| SPECIAL INSTRUCTIONS | | | | |
| 1 | Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work. | ✓ | | |
| TO BE PERFORMED AT EACH INSPECTION SERVICE | | | | |
| 1 | Disconnect the power to the unit. | ✓ | | |
| 2 | Remove the intake grille by removing all screws around the edges. | ✓ | | |
| 3 | Vacuum and wash (if necessary) to remove the buildup of dirt and debris. | ✓ | | |
| 4 | If necessary, lubricate the motors. | ✓ | | |
| 5 | Reinstall the cover and intake grille. | ✓ | | |
| 6 | Verify proper operation of unit. Make and/or recommend any needed repairs. | ✓ | | |

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes: