


PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
EMERGENCY EXIT SIGNS AND WALL PACKS

ACTIVITY AND BLDG #: DE007 B-4

MECHANIC
SIGNATURE: 

DATE: 07/12/22

LOCATION/RM #:

WO# 18307

ASSET #

OY4-177 & 178

START TIME:

0900

FINISH TIME: 1630

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
TO BE PERFORMED AT EACH INSPECTION SERVICE				
1	Inspect for structural defects, note needed repairs	/		
2	Push test buttons and observe light operation. Note any units that do not operate properly.- Report issues and open a CM ticket	/		
3	Clean exterior with dry cloth.	/		
4	For Exit lights check for proper arrow direction.	"/"		
5	Make and/or recommend any needed repairs.	/		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes: