

Tidewater, INC
 DE-007-04
 6625 Selnick Dr.
 Elkridge MD 21075
 (410) 540-8700

Recorded By: Clinton Bates
 (301) 721-2663
 cbates@bondwater.com

Mechanical Room - HVAC Equipment

Test	CT	Closed Loop	City	Glycol Loop
Conductivity (as mmhos)	788 900 - 1350	995 5000 max	538 500 max	4156 5000 max
pH	8.2 7 - 9	9.88 8 - 10.5	7.9 6.5 - 8.3	10.5 8 - 10.5
Chlorides	130 80 - 180		70 50 max	
Hardness, total (ppm as CaCO ₃)	180 750 max		110 200 max	
Alkalinity, total (ppm as CaCO ₃)	100 400 max		80 120 max	
Molybdate (ppm as Mo)		0 50 - 200		
Conductivity Cycles (Calculated)	1.5 3 - 5			
Phosphonate (ppm as PO ₄)	12 5 min			

Opening Comment

Performed monthly scheduled service visit. PM services completed. No flow on the tower system at the time of service.

Inventory reviewed, loop treatment needed.

Glycol loop in good condition.

Closed Loop

Online 

Customer to confirm contractor responsibilities for initial loop treatment. Plan to bring Rx for next service. B5012 Nitrite/Toly blend.

Bond Water Technologies, Inc. recommends that you perform regular and/or daily analysis to control chemical levels and cycles of concentration within established limits. Test results reflect conditions during the point in time when the analysis was performed. Additional testing may be performed upon request. As operating conditions vary, test results will change over time. Notwithstanding anything to the contrary contained in the Agreement or otherwise, (i) Bond Water Technologies and its insurers are not liable for losses caused by the Customers wrongful acts or omissions, (ii) Bond's program does not cover and it makes no guarantees with respect to waterborne pathogens including Legionella or against health risks therefrom, and (iii) in no event shall either party be liable for any consequential or indirect damages.