

Tidewater, INC
DE-007
1001 Ogletown Rd.
Newark DE 19711
(410) 540-8700

Recorded By: Jon Miller
(301) 580-9820
jmillier@bondwater.com

Boiler Room - HVAC Equipment

Test	Hot Loop	Chill Loop		
Conductivity (as mmhos)	3975 3500 max	3195 3500 max		
pH	9.5 8 - 10.5	9.2 8 - 10.5		
Molybdate (ppm as Mo)	200 50 min	200 50 min		

Opening Comment

Performed February scheduled service visit.

Service performed by Technician: Abe Patz

Hot Water Loop

Online 

Corrosion inhibitor residual is excellent at this time. All readings indicate good levels of protection for closed system.

Chill Water Loop

Offline 

Corrosion inhibitor residual is excellent at this time. All readings indicate good levels of protection for closed system. Chill Loop is Offline