

Tidewater, INC
DE-007
1001 Ogletown Rd.
Newark DE 19711
(410) 540-8700

Recorded By: Jon Miller
(301) 580-9820
jmillier@bondwater.com

Boiler Room - HVAC Equipment

Test	Hot Loop	Chill Loop		
Conductivity (as mmhos)	3350 3500 max	2890 3500 max		
pH	10.0 8 - 10.5	9.7 8 - 10.5		
Molybdate (ppm as Mo)	200 50 min	180 50 min		

Opening Comment

Performed monthly scheduled service visit.

Service performed by Technician: Abe Patz

Samples of each glycol loop were sent off to verify condition of glycol.

Hot Water Loop

Offline 

Corrosion inhibitor residual is excellent at this time. All readings indicate good levels of protection for closed system. Hot Loop is Offline

Chill Water Loop

Online 

Corrosion inhibitor residual is excellent at this time. All readings indicate good levels of protection for closed system.