

Tina Lee

From: John Brown <john.brown@tideh2o.net>
Sent: Thursday, May 12, 2022 12:26 PM
To: Tina Lee
Subject: WO 17228 Zone 2 Chiller updates need daily

CAUTION: This email has been received from outside of CMI - Use caution before clicking on links, opening attachments, or responding.

Tina,
Per Brian. DE007 chiller is up and running with no corrective tickets needed.

Thanks,

John Brown
HVAC Technician
TIDEWATER, INC.

john.brown@tideh2o.net

C: 443-346-4349

----- Original message -----
From: Richard Hicks <richard.hicks@cmimgmt.com>
Date: 5/11/22 15:22 (GMT-05:00)
To: John Brown <john.brown@tideh2o.net>, Mary Lowery <Mary.Lowery@tideh2o.net>, Karlee Demain <karlee.demain@tideh2o.net>, Shara Fortier <Shara.Fortier@tideh2o.net>, Ryan Willis <Ryan.Willis@tideh2o.net>, Tina Lee <Tina.Lee@cmimgmt.com>
Cc: Adam Colopy <adam.colopy@tideh2o.net>
Subject: [EXTERNAL]Zone 2 Chiller updates need daily

CAUTION: External email, DO NOT click on any links/attachments unless you recognize the sender and know the content is safe

John ,
Please get Tina daily chiller updates , before you and Brian leave for the day . We are updating the 99th daily . FYI -I’m off until Wednesday next week .

- **Is the chiller online ?**
- **Do we need a ticket for corrective maintenance ?**

Zone	Location	WO #	Asset #	PM #	Manufacturer	Asset Description	Tech Name/ Company	Tech Scheduled Onsite	Not
Z2	DE007-01	17228	1739	PM-SA-1760	York	J-1502000-04 1-pc Chiller, Air Cooled	John / S&S	MAY 12TH	
Z2	MD002-01	17230	1814	PM-SA-1803	York	J-1502000-04 1-pc Chiller, Air Cooled	John / S&S	MAY 13TH	
Z2	MD019-01	17236	2047	PM-SA-2053	York	J-1502000-04 1-pc Chiller	John / S&S	MAY 16TH	

Thanks,
Rick

Rick Hicks
Project Manager Region 5
CMI Management Inc.
5285 Shawnee Road Suite #510
Alexandria,VA 22312
703-738-5301

