

OTHER RECURRING SERVICES CERTIFICATION OF WORK
(To be completed by the Contractor and saved in the Contractor's CMMS)

FacID/Building: MD006

Date of Visit: 12/4/18

Contractor Personnel on Site:

1. <u>Tony Lazarus</u>	4. <u>Frank Srpierz</u>
2. <u>Jim Geertgens</u>	5. _____
3. <u>Scott Werry</u>	6. _____

Work Performed:

Other Recurring Services

1. <u>6520</u>	<u>6710</u>
2. <u>6561</u>	<u>6644</u>
3. <u>6640</u>	
4. <u>6592</u>	

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Jim Geertgens Date: 12-4-18

Signed: Jim Geertgens

To be signed by Facility Manager:

By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Jesse Schultz, ARA Date: 2018/12/04

Signed: Jesse Schultz

E-Mail:

ATTACHMENT J-0200000-05
FORMS

CERTIFICATION OF WORK
(To be completed by the Contractor and saved in the Contractor's CMMS)

FACID/Building: MD 006

Date of Visit: 12/4/18

Contractor Personnel on Site:

1. Tony Geertgens
2. Jim Geertgens
3. Scott Werry

4. Frank Sopranz
5. _____
6. _____

Work Performed:

Preventive Maintenance - Services Completed (Annual, Quarterly, Monthly, equipment identification, etc.)

1. 6488
2. _____
3. _____
4. _____

CERTIFICATION OF WORK

To be signed by the Contractor:

Print Name: Jim Geertgens

Date: 12-4-18

Signed: 

To be signed by Facility Manager:


By signing the Certification of Work, the said government representative signature does not constitute acceptance of any work performed by the contractor, it only acknowledges that the contractor was on-site during the identified timeline:

Print Name/Rank: Jesse Schultz ARA Date: 2018/12/04

Signed: 

E-Mail:

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
FAN COIL UNIT/ DUCTLESS MINI SPLIT

SITE AND BLDG #: MD 006 - 1LOCATION/RM #: 108WO# 6640ASSET # 3964MECHANIC
SIGNATURE: DATE: 12/4/18START TIME: 9:00FINISH TIME: 9:20

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE	NOTES/ ACTIONS	
			OF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION	

- 1 In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.
- 2 Schedule shutdown with operating personnel, as needed.
- 3 As needed, de-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work. Follow lock out/tag out procedures at all times.

- 1 Check fan blades for dust buildup and clean if necessary.
- 2 When applicable, check fan blades and moving parts for cracks and excessive wear.
- 3 Tighten all electrical connectors to proper torque as needed.
- 4 Check that the fan runs properly in all speeds as applicable.
- 5 Check dampers and rotating auto diffusers for dirt accumulations, clean as necessary. Check felt, repair or replace as necessary.
- 6 Check damper actuators and linkage for proper operation as applicable. Adjust linkage on dampers if out of alignment.
- 7 Lubricate mechanical connections of dampers sparingly as applicable.
- 8 Check the valve(s) for signs of leakage and proper operation. If leak is detected, submit a UE.
- 9 Clean coils by brushing, blowing, vacuuming, or pressure washing.
- 10 Check coils for leaking, tightness of fittings.
- 11 Use fin comb to straighten coil fins as needed.

K00-046CMI Management Inc.

- 12 Check belts for wear and cracks, adjust tension or alignment as applicable. Replace belts when necessary.
- 13 Check rigid couplings for alignment on direct drives, and for tightness of assembly.
- 14 Vacuum interior of unit.
- 15 Check filter door for proper gasketing and air leaks. Correct as necessary.
- 16 Change the filter as needed with the correct size and type filter.
- 17 Insure that drain(s) are clear and running.
- 18 Clean up work area.

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency. To be performed by: General Maintenance Worker
 Additional Notes:

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
FAN COIL UNIT/ DUCTLESS MINI SPLIT

SITE AND BLDG #: MD - 006 - 01

MECHANIC
SIGNATURE:

DATE: 12/4/18

LOCATION/RM #: 109 WO# 6646

ASSET # 3965

START TIME:

920

FINISH TIME: 930

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE YES NO	NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)	

- 1 In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.
- 2 Schedule shutdown with operating personnel, as needed.
- 3 As needed, de-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work. Follow lock out/tag out procedures at all times.
- 4 Check fan blades for dust buildup and clean if necessary.
- 5 When applicable, check fan blades and moving parts for cracks and excessive wear.
- 6 Tighten all electrical connectors to proper torque as needed.
- 7 Check that the fan runs properly in all speeds as applicable.
- 8 Check dampers and rotating auto diffusers for dirt accumulations, clean as necessary. Check felt, repair or replace as necessary.
- 9 Lubricate mechanical connections of dampers sparingly as applicable.
- 10 Check the valve(s) for signs of leakage and proper operation. If leak is detected, submit a UE.
- 11 Clean coils by brushing, blowing, vacuuming, or pressure washing.
- 12 Check coils for leaking, tightness of fittings.
- 13 Use fin comb to straighten coil fins as needed.

920

N/A

N/A

N/A

N/A

N/A

N/A

N/A

- 14 Vacuum interior of unit.
- 15 Check filter door for proper gasketing and air leaks. Correct as necessary.
- 16 Change the filter as needed with the correct size and type filter.
- 17 Insure that drain(s) are clear and running.
- 18 Clean up work area.

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

Additional Notes:

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
FAN COIL UNIT/ DUCTLESS MINI SPLIT

SITE AND BLDG #:

MD 006 -01

LOCATION/RM #:

107

WO# 6640

ASSET # 3966

MECHANIC
SIGNATURE:

DATE: 12/4/12

START TIME:

930

FINISH TIME: 940

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE YES NO	NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)

- 1 In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.
- 2 Schedule shutdown with operating personnel, as needed.
- 3 As needed, de-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work. Follow lock out/tag out procedures at all times.

- 1 Check fan blades for dust buildup and clean if necessary.
- 2 When applicable, check fan blades and moving parts for cracks and excessive wear.
- 3 Tighten all electrical connectors to proper torque as needed.
- 4 Check that the fan runs properly in all speeds as applicable.
- 5 Check dampers and rotating auto diffusers for dirt accumulations, clean as necessary. Check felt, repair or replace as necessary.
- 6 Check damper actuators and linkage for proper operation as applicable. Adjust linkage on dampers if out of alignment.
- 7 Lubricate mechanical connections of dampers sparingly as applicable.
- 8 Check the valve(s) for signs of leakage and proper operation. If leak is detected, submit a UE.
- 9 Clean coils by brushing, blowing, vacuuming, or pressure washing.
- 10 Check coils for leaking, tightness of fittings.
- 11 Use fin comb to straighten coil fins as needed.

K00-046CMI Management Inc.

- 12 Check belts for wear and cracks, adjust tension or alignment as applicable. Replace belts when necessary.
- 13 Check rigid couplings for alignment on direct drives, and for tightness of assembly.
- 14 Vacuum interior of unit.
- 15 Check filter door for proper gasketing and air leaks. Correct as necessary.
- 16 Change the filter as needed with the correct size and type filter.
- 17 Insure that drain(s) are clear and running.
- 18 Clean up work area.

NA

NA

NA

NA

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency. To be performed by: General Maintenance Worker

Additional Notes:

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
FAN COIL UNIT/ DUCTLESS MINI SPLIT

SITE AND BLDG #: MD 006-01

LOCATION/RM #: 106

WO# 6640

ASSET # 3967

MECHANIC
SIGNATURE:
James H. S.

START TIME: 940

DATE: 12-4-18

FINISH TIME: 950

NOTES/ACTIONS
(IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE YES NO
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	/
2	Schedule shutdown with operating personnel, as needed.	/
3	As needed, de-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work. Follow lock out/tag out procedures at all times.	/
4	Check fan blades for dust buildup and clean if necessary.	NR
5	When applicable, check fan blades and moving parts for cracks and excessive wear.	NA
6	Tighten all electrical connectors to proper torque as needed.	NA
7	Check that the fan runs properly in all speeds as applicable.	NA
8	Check dampers and rotating auto diffusers for dirt accumulations, clean as necessary. Check felt, repair or replace as necessary.	NA
9	Check damper actuators and linkage for proper operation as applicable. Adjust linkage on dampers if out of alignment.	NA
10	Lubricate mechanical connections of dampers sparingly as applicable.	NA
11	Check the valve(s) for signs of leakage and proper operation. If leak is detected, submit a UE.	NA
12	Clean coils by brushing, blowing, vacuuming, or pressure washing.	NA
13	Check coils for leaking, tightness of fittings.	NA
14	Use fin comb to straighten coil fins as needed.	NA

K00-046CMI Management Inc.

- 12 Check belts for wear and cracks, adjust tension or alignment as applicable. Replace belts when necessary.
- 13 Check rigid couplings for alignment on direct drives, and for tightness of assembly
- 14 Vacuum interior of unit.
- 15 Check filter door for proper gasketing and air leaks. Correct as necessary.
- 16 Change the filter as needed with the correct size and type filter.
- 17 Insure that drain(s) are clear and running.
- 18 Clean up work area.

NA

NA

/

/

NA

/

/

/

/

/

/

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency. To be performed by: General Maintenance Worker

Additional Notes:

not preped in no hot water.

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
FAN COIL UNIT/ DUCTLESS MINI SPLIT

SITE AND BLDG #: MD 008-0

LOCATION/RM #: 103

WO# 6640

ASSET # 3968

MECHANIC
SIGNATURE:
Anthony

START TIME: 950

DATE: 12/4/18

FINISH TIME: 0000

NOTES/ ACTIONS
(IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE YES	TASK COMPLETE NO	NOTES/ ACTIONS
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	/	/	
2	Schedule shutdown with operating personnel, as needed.	/	/	
3	As needed, de-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work. Follow lock out/tag out procedures at all times.	/	/	
4	Check fan blades for dust buildup and clean if necessary.	/	/	
5	When applicable, check fan blades and moving parts for cracks and excessive wear.	/	/	
6	Tighten all electrical connectors to proper torque as needed.	/	/	
7	Check that the fan runs properly in all speeds as applicable.	/	/	
8	Check dampers and rotating auto diffusers for dirt accumulations, clean as necessary. Check felt, repair or replace as necessary.	/	/	N/A
9	Check damper actuators and linkage for proper operation as applicable. Adjust linkage on dampers if out of alignment.	/	/	N/A
10	Lubricate mechanical connections of dampers sparingly as applicable.	/	/	N/A
11	Check the valve(s) for signs of leakage and proper operation. If leak is detected, submit a UE.	/	/	N/A
12	Clean coils by brushing, blowing, vacuuming, or pressure washing.	/	/	N/A
13	Check coils for leaking, tightness of fittings.	/	/	N/A
14	Use fin comb to straighten coil fins as needed.	/	/	N/A

K00-046CMI Management Inc.

- Check belts for wear and cracks, adjust tension or alignment as applicable. Replace belts when necessary.
- Check rigid couplings for alignment on direct drives, and for tightness of assembly
- Vacuum interior of unit.
- Check filter door for proper gasketing and air leaks. Correct as necessary.
- Change the filter as needed with the correct size and type filter.
- insure that drain(s) are clear and running.
- Clean up work area.

N/A

/

/

/

/

/

/

/

/

/

/

/

/

/

/

/

/

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency. To be performed by: General Maintenance Worker
Additional Notes:

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
FAN COIL UNIT/ DUCTLESS MINI SPLIT

SITE AND BLDG #: MD 606 -a

LOCATION/RM #: 103

WO# 6640

ASSET # 3869

MECHANIC
SIGNATURE: *James P. D.*

DATE: 12/4/18

START TIME: 0000

FINISH TIME: 1010

NOTES/ACTIONS
(IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE YES	TASK COMPLETE NO	NOTES/ACTIONS
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	/	/	
2	Schedule shutdown with operating personnel, as needed.	/	/	
3	As needed, de-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work. Follow lock out/tag out procedures at all times.	/	/	
4	Check fan blades for dust buildup and clean if necessary.	/	/	
5	When applicable, check fan blades and moving parts for cracks and excessive wear.	/	/	
6	Tighten all electrical connectors to proper torque as needed.	/	/	
7	Check that the fan runs properly in all speeds as applicable.	/	/	
8	Check dampers and rotating auto diffusers for dirt accumulations, clean as necessary. Check felt, repair or replace as necessary.	/	/	N/A
9	Check damper actuators and linkage for proper operation as applicable. Adjust linkage on dampers if out of alignment.	/	/	N/A
10	Lubricate mechanical connections of dampers sparingly as applicable.	/	/	
11	Check the valve(s) for signs of leakage and proper operation. If leak is detected, submit a UE.	/	/	
12	Clean coils by brushing, blowing, vacuuming, or pressure washing.	/	/	
13	Check coils for leaking, tightness of fittings.	/	/	
14	Use fin comb to straighten coil fins as needed.	/	/	N/A

K00-046CMI Management Inc.

- Check belts for wear and cracks, adjust tension or alignment as applicable. Replace belts when necessary.
- Check rigid couplings for alignment on direct drives, and for tightness of assembly.
- Vacuum interior of unit.
- Check filter door for proper gasketing and air leaks. Correct as necessary.
- Change the filter as needed with the correct size and type filter.
- insure that drain(s) are clear and running.
- Clean up work area.

N/A

/

/

/

/

N/A

/

/

/

/

/

/

/

/

/

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency. To be performed by: General Maintenance Worker
Additional Notes:

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
FAN COIL UNIT/ DUCTLESS MINI SPLIT

SITE AND BLDG #: MD 006-01

LOCATION/RM #: Freezer WO# 6640

ASSET # 3970

MECHANIC
SIGNATURE: *John L. Hobbs*

DATE: 12/4/18

START TIME: 1010

FINISH TIME: 1020

NOTES/ ACTIONS
(IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE YES	TASK COMPLETE NO	NOTES/ ACTIONS
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	/		
2	Schedule shutdown with operating personnel, as needed.	/		
3	As needed, de-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work. Follow lock out/tag out procedures at all times.	/		
4	Check fan blades for dust buildup and clean if necessary.	/		
5	When applicable, check fan blades and moving parts for cracks and excessive wear.	/		
6	Tighten all electrical connectors to proper torque as needed.	/		
7	Check that the fan runs properly in all speeds as applicable.	/		
8	Check dampers and rotating auto diffusers for dirt accumulations, clean as necessary. Check felt, repair or replace as necessary.	/		NA
9	Check damper actuators and linkage for proper operation as applicable. Adjust linkage on dampers if out of alignment.	/		NA
10	Lubricate mechanical connections of dampers sparingly as applicable.	/		
11	Check the valve(s) for signs of leakage and proper operation. If leak is detected, submit a UE.	/		
12	Clean coils by brushing, blowing, vacuuming, or pressure washing.	/		
13	Check coils for leaking, tightness of fittings.	/		
14	Use fin comb to straighten coil fins as needed.	/		NA

K00-046CMI Management Inc.

- Check belts for wear and cracks, adjust tension or alignment as applicable. Replace belts when necessary.
- Check rigid couplings for alignment on direct drives, and for tightness of assembly
- Vacuum interior of unit.
- Check filter door for proper gasketing and air leaks. Correct as necessary.
- Change the filter as needed with the correct size and type filter.
- Ensure that drain(s) are clear and running.
- Clean up work area.

NA

NA

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.
To be performed by: General Maintenance Worker
Additional Notes:

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
FAN COIL UNIT/ DUCTLESS MINI SPLIT

SITE AND BLDG #: MD 006-01

LOCATION/RM #: 105

WO# 6640

ASSET # 3971

MECHANIC
SIGNATURE:


DATE: 12/4/18

FINISH TIME: 1030

START TIME: 1020

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE YES	TASK COMPLETE NO	NOTES/ ACTIONS
				OF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	/	/	
2	Schedule shutdown with operating personnel, as needed.	/	/	
3	As needed, de-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work. Follow lock out/tag out procedures at all times.	/	/	
1	Check fan blades for dust buildup and clean if necessary.	/	NP	
2	When applicable, check fan blades and moving parts for cracks and excessive wear.	/	NA	
3	Tighten all electrical connectors to proper torque as needed.	/		
4	Check that the fan runs properly in all speeds as applicable.	/		
5	Check dampers and rotating auto diffusers for dirt accumulations, clean as necessary. Check felt, repair or replace as necessary.	/		
6	Check damper actuators and linkage for proper operation as applicable. Adjust linkage on dampers if out of alignment.	/	NA	
7	Lubricate mechanical connections of dampers sparingly as applicable.	/		
8	Check the valve(s) for signs of leakage and proper operation. If leak is detected, submit a UE.	/	NA	
9	Clean coils by brushing, blowing, vacuuming, or pressure washing.	/		
10	Check coils for leaking, tightness of fittings.	/		
11	Use fin comb to straighten coil fins as needed.	/	NA	

K00-046CMI Management Inc.

- 12 Check belts for wear and cracks, adjust tension or alignment as applicable. Replace belts when necessary.
- 13 Check rigid couplings for alignment on direct drives, and for tightness of assembly
- 14 Vacuum interior of unit.
- 15 Check filter door for proper gasketing and air leaks. Correct as necessary.
- 16 Change the filter as needed with the correct size and type filter.
- 17 insure that drain(s) are clear and running.
- 18 Clean up work area.

NA

NA

/

/

/

/

/

/

/

/

/

/

/

/

/

/

/

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency. To be performed by: General Maintenance Worker

Additional Notes:

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
FAN COIL UNIT/ DUCTLESS MINI SPLIT

SITE AND BLDG #: MD 006 -01

LOCATION/RM #: 101 WO# 6640

ASSET # 3972

MECHANIC
SIGNATURE:
James

DATE: 12/4/18

START TIME: 1030

FINISH TIME: 1040

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	

- 1 In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.
- 2 Schedule shutdown with operating personnel, as needed.
- 3 As needed, de-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work. Follow lock out/tag out procedures at all times.

- 1 Check fan blades for dust buildup and clean if necessary.
- 2 When applicable, check fan blades and moving parts for cracks and excessive wear.
- 3 Tighten all electrical connectors to proper torque as needed.
- 4 Check that the fan runs properly in all speeds as applicable.
- 5 Check dampers and rotating auto diffusers for dirt accumulations, clean as necessary. Check felt, repair or replace as necessary.
- 6 Check damper actuators and linkage for proper operation as applicable. Adjust linkage on dampers if out of alignment.
- 7 Lubricate mechanical connections of dampers sparingly as applicable.
- 8 Check the valve(s) for signs of leakage and proper operation. If leak is detected, submit a UE.
- 9 Clean coils by brushing, blowing, vacuuming, or pressure washing.
- 10 Check coils for leaking, tightness of fittings.
- 11 Use fin comb to straighten coil fins as needed.

K00-046CMI Management Inc.

- 12 Check belts for wear and cracks, adjust tension or alignment as applicable. Replace belts when necessary.
- 13 Check rigid couplings for alignment on direct drives, and for tightness of assembly.
- 14 Vacuum interior of unit.
- 15 Check filter door for proper gasketing and air leaks. Correct as necessary.
- 16 Change the filter as needed with the correct size and type filter.
- 17 insure that drain(s) are clear and running.
- 18 Clean up work area.

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.
 To be performed by: General Maintenance Worker
 Additional Notes:

PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST
FAN COIL, UNIT/ DUCTLESS MINI SPLIT

SITE AND BLDG #:

M006-C1

LOCATION/RM #:

101 WO# 6640

ASSET # 3973

MECHANIC
SIGNATURE:
James W. S.

DATE:

12/4/18

START TIME:

1040

FINISH TIME: 1050

NOTES/ ACTIONS
(IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE YES NO
1	In addition to the procedure(s) outlined in this standard, the equipment manufacturer's recommended maintenance procedure(s) and/or instruction(s) shall be strictly adhered to.	/
2	Schedule shutdown with operating personnel, as needed.	/
3	As needed, de-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work. Follow lock out/tag out procedures at all times.	/
4	Check fan blades for dust buildup and clean if necessary.	/
5	When applicable, check fan blades and moving parts for cracks and excessive wear.	/
6	Tighten all electrical connectors to proper torque as needed.	/
7	Check that the fan runs properly in all speeds as applicable.	/
8	Check dampers and rotating auto diffusers for dirt accumulations, clean as necessary. Check felt, repair or replace as necessary.	/
9	Check damper actuators and linkage for proper operation as applicable. Adjust linkage on dampers if out of alignment.	/
10	Lubricate mechanical connections of dampers sparingly as applicable.	/
11	Check the valve(s) for signs of leakage and proper operation. If leak is detected, submit a UE.	/
	Clean coils by brushing, blowing, vacuuming, or pressure washing.	/
	Check coils for leaking, tightness of fittings.	/
	Use fin comb to straighten coil fins as needed.	/

K00-046CMI Management Inc.

- 12 Check belts for wear and cracks, adjust tension or alignment as applicable. Replace belts when necessary.
- 13 Check rigid couplings for alignment on direct drives, and for tightness of assembly
- 14 Vacuum interior of unit.
- 15 Check filter door for proper gasketing and air leaks. Correct as necessary.
- 16 Change the filter as needed with the correct size and type filter.
- 17 Insure that drain(s) are clear and running.
- 18 Clean up work area.

NA

NA

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency. To be performed by: General Maintenance Worker
Additional Notes: