

**PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST**  
**DEHUMIDIFIER**

SITE AND BLDG #: **NY013 BLDG1**MECHANIC  
SIGNATURE:DATE: **1/23/23**LOCATION/RM #: **vault** WO# **20507** ASSET # **9215**START TIME: **8:30am**FINISH TIME: **9am**

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
<b>SPECIAL INSTRUCTIONS</b>				
1	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	✓		
<b>TO BE PERFORMED AT EACH INSPECTION SERVICE</b>				
1	Check water inlet and outlet for any leaks, repair as needed.	✓		
2	Clean and/or replace filter as needed. -Record space humidity	✓		Space Humidity <u>52</u> %
3	If applicable, check hours per usage, replace tanks as needed.	✓		

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

**Additional Notes:**