

**PREVENTATIVE MAINTENANCE PROGRAM CHECKLIST**  
**DEHUMIDIFIER**

**SITE AND BLDG #:** NY051 BLDG1      **MECHANIC SIGNATURE:**   
**LOCATION/RM #:** vault      **WO#** 23313      **ASSET #** 190917-285      **DATE:** 7/7/23  
**START TIME:** 10:30am      **FINISH TIME:** 11am

CHECK POINT	CHECKPOINT DESCRIPTION	TASK COMPLETE		NOTES/ ACTIONS (IF TASK COMPLETE IS CHECKED NO, PROVIDE EXPLANATION)
		YES	NO	
<b>SPECIAL INSTRUCTIONS</b>				
1	Follow lock out/tag out procedures at all times. De-energize or discharge all hydraulic, electrical, mechanical, or thermal energy prior to beginning work.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
<b>TO BE PERFORMED AT EACH INSPECTION SERVICE</b>				
1	Check water inlet and outlet for any leaks, repair as needed.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
2	Clean and/or replace filter as needed. -Record space humidity	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Space Humidity <u>56%</u> %
3	If applicable, check hours per usage, replace tanks's as needed.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	

Note: The technician shall perform any repairs identified during PM up to \$250 (direct labor and direct material cost) per PM occurrence. For any deficiencies found exceeding \$250 open a corrective maintenance (CM) ticket and include the Asset #, WO #, photos, and a detailed description of the deficiency.

To be performed by: General Maintenance Worker

**Additional Notes:**

The dehumidifier is not functioning properly And I am Putting in a request to replace it.